Bryan

BH-Series Electric Boilers

How Water or Steam







Bryan electric hot water or steam boilers... A capacity for most applications

BS Series



Our Bryan electric hot water or steam boilers provide fast, efficient and economical heating for office buildings, apartment houses, schools. hospitals, factories, swimming pools and many other commercial and industrial applications. These advanced boilers combine the advantage of modern electric operation with hydronic or steam heating to create an entirely new concept in complete comfort engineering. By simply adding a chiller or heat pump to your modern Bryan-equipped hydronic or steam system, you can have year 'round air conditioning.

The Bryan Electric Steam Boiler is ideally suited for high or low pressure precess steam. Hospitals, dairies, restaurants, laundries, dry cleaners, food processing' tire recapping and metal plating are just a few of the possible applications.

Fully automatic Bryan Electric Boilers are specifically designed to meet the performance standards dictated by specifying engineers.

Bryan electric-powered boilers eliminate soot, flues, vents. fuel storage tanks, oil lines and gas piping. Boiler room space can be kept to a minimum. In Bryan Electric Boilers, postulating controls automatically actuate the heating elements to maintain the precise system temperature or steam

Our boilers are also delivered to your job site precised, preassembled and thoroughly factory-tested.

Electric Heating Elements

The immersion-type electric resistance heating elements used in the Bryan Boilers are mounted in a standard 150-lb flange, held with thread fittings. Each element is rated at 5 or 10 KW at the rated volts and has an Incoloy sheath composed Of nickel, chrome and iron alloy.

> 5 or 10 KW hairpin heating element. Each element replaceable with hand tools. Incoloy-sheathed — 75 watts/sq in.

> > Spacing disc to provide support and proper circulation around individual elements.





This superior sheath provides excellent resistance to oxidation and has particularly good strength characteristics at elevated temperatures. For comparison, the following are maximum temperature limits for several of the sheath materials normally used: Copper—350°, Steel—750°F, Type 304 Stainless Steel—1400°F, Incoloy—1800°F.
By virtue of its relatively high nickel content, the Incoloy does not become


brittle after prolonged exposure to temperatures. Corrosion resistance of the Incoloy is attributed to the chrome and nickel content of the alloy. This material is highly resistant to corrosion, oxidation and attack caused by various water impurities.

If you do burn out one of our elements, your maintenance man can replace it easily with hand tools. Being able to easily replace individual elements eliminates the need for stocking a complete element bundle of spares and the expense and inconvenience of hav-ing to return the element bundle to the manufacturer for repair All Bryan BH Series boilers feature copper bus bar distribution, wherein the fuse clip for each branch circuit and the main power lugs are all bolted directly to a bus bar The bus bar can carry the full load current of the boiler withstanding the largest available fault current from the entering power system. Use of the bus bar protects all current-carrying pads and prevents damage to the boiler.

We produce an outstanding line of boilers. We invite any comparison.







Construction Features

A. Heavy steel pressure vessel, built and stamped in accordance with ASME Boiler Cre. 125 psi and 150 psi design standard On hot water boilers. 15 psi Or 125 psi and 150 psi standard On steam boilers. Higher pressure available upon application.

B. Heating element bundles-immersion type-mounted on standard 150-lb. ANSI flanges. Individual elements replaceable with hand tools. Element watt density is 75 watts/sq. in. Of surface area. Incoloy-sheathed.

- C. Boiler jacket I6-gauge/zinc coated, rust-resistant primer and attractive enamel finish.
- D. Heavy boiler insulation—4" fiberglass.
- E. Power panel contains main busing, Entrance lugs, Class J fuses and

magnetic compactors.

- F. Control panel contains maculating step controller, control transformer, recycle relay, control circuit fuse and on-off control circuit switch.
- G. Low water cutoff or combination low water cutoff and pump control.
- H. clanged flow and return connections.
- I. Relief valve.
- J. Temperature and pressure gauge.
- K. Structural steel base.
- L. Sequence indicating lights.
- M. Alarm bell (optional).

Standard Equipment

Modulating step controller • Operating control • High limit control • Low water cutoff • Magnetic contactors • 4" fiberglass boiler insulation • Heavy-duty copper internal busing • JKS fusing • Pilot lights—one per step • Bus lugs • ASME safety relief valve • Control

transformer • Recycle relay • On-Off control switch • Incoloy-sheather, immersion type heating elements • Lifting lugs • 16-gauge steel jacket • Key-operate lock in handle of power panel • Factory assembled and tested.

Optional Equipment

Solid state, First On-First Off progressive sequencing step control • Power panel door interlock • Preheat switch • Ammeter—one phase or three phase • Voltmeter—one or three phase • Time clock—24 hrs or seven day • Flow switch • Outdoor reset control • Manual reset high limit control • Low water cutoff drain valve • Boiler drain or blowdown valve • Manufal reset low water cut-off • Operational hour meter (running time) • Lead-lag control • Kilowatt limiter based on outdoor temperature • Ground fault protection • Automatic boiler

blowdown valve • Manhole—when not furnished as standard (Standard on 125 and 150 psi steam) • Alarm bell (specify function) • Alarm silencing switch • Special indicating lights • Factory operating test • Boiler feed system • Combination low water cutoff and feeder • Auxillary low water cutoff • National Board stamping • Other than standard size inlet and outlet • 50-watt density heating elements.



Sample specifications for electric hot water or steam* boilers.

General

Furnish and install where shown on the plans (1, 2, 3, etc.) package type electric hot water (steam)* boiler(s) Model as manufactured by Bryan Steam Corporation. Unit shall be completely factory assembled including accessories as described herein, precised, factory tested and U.L. labeled.

Each boiler herein shall have an input of _____ KW at _____ volts. The pressure vessel, insulation, jacket, electrical cabinet(s) and control cabinet shall be mounted on a unitary structural steel frame. Each boiler shall be equipped with a dial type panel mounted temperature gauge and pressure gauge (pressure gauge only for steamed.

Pressure vessel

The pressure vessel shall be of all-welded steel construction, designed for a pressure of psig in accordance with the ASME Boiler & Pressure Vessel Code and stamped with the appropriate ASME symbol.

The vessel shall be provided with:

The necessary inspection openings as required by the ASME Code, lifting lug(s), openings for flanged elements and controls, four inches of fiberglass insulation, wire netting to hold insulation in place, drain line of a size as required by the ASME Code, flanged outlet inch pipe size, flanged inlet inch pipe size, ASME safety relief velvets) with capacity and size as required by the ASME Code, set to relieve at prig. A 16 ga. zinc coated metal jacket painted with two coats of enamel.


Electrical

(An) electrical power panel cabinet(s) shall be provided. There shall be no operating nor limit controls mounted in this cabinet. It shall be equipped with louvers which will facilitate natural air circulation to minimize temperature rise. The cabinet hinged doors shall be equipped with a key lock handle to prevent access by unauthorized personnel, The main power supply to the boiler shall be from _______ (1, 2, 3, etc.) sources and shall be ______ (208, 240, 480, etc.) volts, 3 phase, 60 Hz, 3 wire system supplied to the electrical cabinet(s) by ______ (1, 2, 3, etc.) ______ (250, 350, 500, eta) MCM conductors per phase and the copper bus bars located in the cabinet(s) shall be equipped with lugs to accommodate these incoming conductors.

The distribution of power within the unit shall be from the copper bus bar through class "J" fuses, through magnetic compactors to the elements. The class "J"fuses shall be installed in fuse clips having a reinforcing member. One of the fuse clips for each fuse shall be mounted directly on the copper bus bar and the other clip shall be mounted on a laminated insulating bar All power wiring in the unit shall terminate in the box type connectors. Crimp connectors in the ewer circuit will not be acceptable. The power wiring from the class "J" fuses to the magnetic contacted shall be of a size not less than number 8 AWG with insulation of a rating not less than 90°C.

Flements

The boiler shall be equipped with immersion type heating elements mounted in standard 150 lb. A.N.S.I. flanges. Each element shall be



mechanically mounted and field replaceable without welding or brazing. Elements shall be Incoloy sheathed and have maximum watt density of 75 wads per square inch. Elements shall be rated for voltage specified.


Controls


A control cabinet shall be provided. The control circuit shall be 120 volts, single phase, 60 Hz, supplied by a stepdown transformer of the proper size. Both sides of the control transformer primary shall be protected by class "J" fuses located in the electrical cabinet. One side of the control transformer secondary shall be grounded and the other side fused. The control circuit shall also include:

An on-off switch to shut off current to controls, high limit control which will interrupt control circuit if operating operating conditions are exceeded, low water cutoff, recycle relay which will, in case of circuit interruption, cause the modulating step controller to modulate to the start position before the circuit will be re-energized, modulating step controller will be re-energized modulating step controller with (3, 5, 7, eta) steps, and (1) Indicating light for each step of the step

The operating control shall be set to maintain an outlet temperature (pressure steam)* of _____°F (PSI Steam)*.

Bryan BH-Series Electric Boilers **Dimensions And Ratings**





В	iler	Total I	1	Dimensions - Hot Water Boilers								Fluid Power Panel*						Dimensions - Steam Boilers										Ct-I					Approximate									
Ь.	illei	208	240	460	480	 -		1		T T		11310113	T	Tel Bolle	T			oacity	A B						L			I	I	I			l G		Std. No.		Standard Bus Lugs			rating	Approximate Shipping	
Input	Output	60	60	60	60	60	208	3 4	180	w	ΙнΙ	С	l _D	E	l F	G		llons	208	460	575	208	460	575	208	480	w l	нΙ	clo	ЬΙΕ	15	125	15	125	Of	(pe	er Phase per Pa	anel)	We	eight	Wei	
1	MBH	3	3	3	3	3	240		160							-	Water	Steam	240	480		240	480			460			1			150	"	150	Steps	208/240/3	460/480/3	575/3	Water	Steam	Water	Steam
60	196	168	146	76	73	61	50	!	50	23	32	111/2	12	15	2	2	24	51	10	10	10	40	40	40	50	50	31	40	151/2 1	5 16	3	2	2	1	4	250MCM	1/0	1/0	1045	1,377	900	1,000
75	245	210	183	%	92	77	50	!	50	23	32	111/2	12	15	2	2	24	51	10	10	10	40	40	40	50	50	31	40	151/2 1	5 16	3	2	2	1	5	350MCM	1/0	1/0	1,045	1,377	900	1,000
90	294	252	219	114	109	91	50	į	50	23	32	111/2	12	15	2	2	24	51	10	10	10	10	40	40	40	50	31	40	151/2 1	5 16	3	2	2	1	3	500MCM	250MCM	1/0	1,144	1,477	1,000	1,100
105	343	294	255	133	127	106	50	ļ	50	23	32	111/2	12	15	2	2	24	51	10	10	10	52	40	40	50	50	31	~	151/2 1	5 16	3	2	2	1	4	500MCM	250MCM	250MCM	1,144	1,677	1,000	1,300
120	393	335	291	152	145	121	50		50	23	32	111/2	12	15	2	2	24	51	10	10	10	52	40	40			31		151/2 1	5 16	3	2	2	1	4	(2)350MCM	250MCM	250MCM	1,144	1,677	1,000	1,300
135	442	377	327	171	164	137	50		50	31	40	151/2	15	16	2	2	51	82	10	10	10	52	40	40					181/2 1	6 17	4	3	3	1	4	(2)350MCM	250MCM	250MCM	1,577	2,025	1,200	1,400
150	491	420	365	190	182	152	50		50	31	40	151/2	15	16	2	2	51	82	10	10	10	52	40	40					181/2 1	6 17	4	3	3	1	4	(2)350MCM	250MCM	250MCM	1,577	2,125	1,200	1,600
165	540	461	401	209	200	165	50		50	3/	46	181/2	16	1/	3	3	82	82	10	10	10	52	40	40	50	50	_		181/2 1	6 1/	4	3	3	1	6	(2)350MCM	250MCM	250MCM	1,935	2,125	1,300	1,500
180	589	503	437	228	219	182	50		50	3/	4b	18/2	16	1/	3	3	82	82	10	10	10	52	40	40	50	50	-	46	18/2	6 1/	4	3	3	1	6	(2)500MCM	350MCM	250MCM	1,935	2,125	1,300	1,500
195	638 687	545	473	247	237	197	50		50	3/	46	181/2	16	17	3	3	82	82	10	10	10	70	52 m	52	50				18/2 1	6 1/	4	3	3	1	7	(2)500MCM (2)500MCM	350MCM	250MCM	2,035	2,225 2,325	1,400	1,600 1,700
210	737	587 629	509 546	266 284	255	212	50 FO	- 1 :	50	27	46	10/2	16	17	3	2	82	02	10	10	10	70	52	52	30 FO		37	46	181/2	6 17	4	3	3	1 1	0	(3)500MCM	500MCM 500MCM	250MCM 350MCM	2,035 2,135	2,325	1,400 1,500	1,700
240	786	671	582	303	291	242	50		50	<u>ာ</u>	20	181/2	16	17	2	3	82	82	10	10	10	70	52	52	50	~	37		181/2	6 17	4	3	3	1	Q	(3)500MCM	500MCM	500MCM	2,135	2,525	1,600	1,900
270	884	785	655	341	327	273	50		50	37	46	181/2	16	17	3	3	82	180	10	10	10	76		52			_		241/2 2	1 17	6	3	6	1	9	(3)500MCM	(2)350MCM	500MCM	2,235	2,754	1,600	2,000
300	982	839	728	380	364	303	56		50	37	46	181/2	16	17	3	3	82	180	10	10	10	76	_	52					241/2 2			3	6	1	10	(3)500MCM	(2)350MCM	500MCM	2,335	2,754	1,700	2,200
330	1081	922	800	417	400	334	56		50	37	46	181/2	16	17	3	3	82	180	10	10	10	73		52					24/2 2			3	6	1	6	(3)500MCM	(2)350MCM	(2)350MCM	2,435	3,054	1,800	2,300
360	1179	1006	873	455	436	364	56		50	37	46	181/2	16	17	3	3	82	180	14	10	10	76	52	52			_		241/2 2		' 6	3	6	1	6	(4)500MCM	(2)350MCM	(2)350MCM	2,435	3,154	1,800	2,400
390	1277	1090	946	492	472	394	80		56	43	52	211/2	18	17	4	4	125	248	14	8	10	86	70	70			55		271/2 2) 6	3	6	11/2	7	(4)500MCM	(2)350MCM	(2)350MCM	2,610	3,565	2,000	2,500
420	1375	1173	1018		508		80		56	43	52	211/2	18	17	4	4	125	248	14	10	10	86	70	70			55		271/2 2) 6	3	6	11/2	7	(4)500MCM	(2)500MCM	(2)350MCM	2,610	3,665	2,000	2,600
450	1474	1257	1091	569	545	445	80		56	43	52	211/2	18	17	4	4	125	248	14	10	10	83	70	70	68	56	55	64	271/2 2	1 19) 6	3	6	11/2	8	(6)500MCM	(2)350MCM	(2)350MCM	2,710	3,765	2,100	2,700
480	1572	1341	1164	606	581	485	80		56	43	52	211/2	18	17	4	4	125	248	14	10	10	86	70	70	74	56	55	64	271/2 2	21 19) 6	3	6	11/2	8	(6)500 MCM	(2)500 MCM	(2)500 MCM	2,760	3,865	2,450	2,800
510	1670	A	A	644	617	516			78	37	46	181/2	21	17	6	6	170	310	14	10	10		70	70		82	43	52	211/2 2	1 19) 6	3	6	11/2	9		(3)500 MCM	(2)500 MCM	3,933	4,450	2,500	2,900
540	1769			682	654	546	1		78	37	46	181/2	21	17	6	6	170	310	1	10	10		70	70		82	43	52	211/2 2	71 19) 6	3	6	11/2	9	1	(3)500 MCM	(3)500MCM	3,983	4,500	2,550	2,950
570	1867			719	690	576	1		78	37	46	181/2	21	17	6	6	170	310		10	10		76	76		82	43	52	211/2 2	21 19) 6	3	6	11/2	10	1	(3)500MCM	(3)500 MCM	4,070	4,550	2,650	3,000
600	1965			758	727	606			78	37	46	181/2	21	17	6	6	170	310		10	10			76			43	52	211/2 2	21 19	6	4	6	11/2	10	1	(3)500MCM	(3)500 MCM	4,120	4,600	2,700	3,050
660	2162			833	799	677			88	43	52	211/2	21	17	6	6	310	310		10	10			76			43		211/2 2			4	6	11/2	11	\perp	(3)500MCM	(3)500MCM	6,385	4,650	3,800	3,100
720	2358			909	871	728	\perp		84	43	52	211/2	21	17	6	6	310	310	$\perp \!\!\! \perp \!\!\! \perp$	10	10			76	$\perp \perp \perp$	82	43	52	211/2 2	2 20) 6	4	6	11/2	12	_\	(3)500MCM	(3)500 MCM	6,485	4,700	3,900	3,150
780	2555			985	944	788	\perp		84	43	52	211/2	21	19	6	6	310	150	11 /	14	14	\perp		86	1 11	84	55	64	241/2 2	2 2	8	4	6	11/2	13	\rightarrow	(4)500MCM	(3)500MCM	6,585	6,230	4,000	4,000
840	2751			1060	1017	849	+		84	43	52	211/2	21	19	6	6	310	450	11 1	14	14	+		86	+		55		241/2 2			4	6	11/2	14	-	(4)500MCM	(3)500MCM	6,685	6,350	4,100	4,100
900	2948			1137	1090		+		84	43	52	211/2	21	19	6	6	310	450	+	14	14	+		86			55	_	241/2 2			4	6	11/2	15	-	(4)500MCM	(3)500MCM	6,785	6,450	4,200	4,200
960	3144			1212	1162		+		84	43	52 52	211/2	21	19	6	6	310	450	++++	14	14	+		86			~		271/2 2	4 21	8	4	6	11/2	16	-\	(4)500MCM	(4)500MCM	6,835	6,650	4,250	4,400
1020	3341			1287 1363	1234	1031	+		84	43	52	211/2	21		6	6	310 450	450	+++	14	14	\mathbf{H}	86	ab ov	+++		55	70	271/2 2	4 2	8	6	6	11/2	17	-	(6)500MCM	(3)500 MCM (3)500 MCM	6,885	7,250	4,300	5,000 5,300
1140	3538 3734	\perp		1439	1307	1092 1150	++		84	30	64	271/2	24	20	6	6	450	600	+++	14	14	+H	86 86	86 86	+H+		61	70	30/2 2	4 ZI	0	6	6	11/2	18 19	-	(6)500MCM (6)500MCM	(3)500IVICIVI	8,750 8,850	8,300 8,400	5,000 5,100	5,400
1200	3931	-≿-	- ≿	1515	1453		+		84	<u></u>	64	271/2	24	20	6	6	450	600	+ + + +	14	14	+H	86	86	+// +		61	_	30/2 2	4 21	0	6	6	11/2	20	- \ 	(6)500MCM	(3)500IVICIVI	8,950	8,500	6,200	5,500
1260	4127	_ <u>ö</u> −	<u> </u>	1590	1525		+ W		84	-5 -	64	271/2	24	20	6	6	450	600	+ 1/	14	14	\forall	86	86	- V 		61	70	301/2 2	M 21	8	1 6	6	11/2	14	1/	(6)500MCM	(3)500MCM	9.050	8,600	5,300	5,600
1320	4324	–ნ–	— ე-	1666	1597	1334	+ ∀		84	<u>~</u>	64	271/2	24	20	6	6	450	600	+ ₩	14	14	\neg	86	86	+ +	<u> </u>	61	70	30/2 2	4 21	8	6	6	11/2	15	- V -	(6)500MCM	(3)500 MCM	9,150	8,700	5,400	5,700
1380	4520	_변_	<u> </u>	1742	1670	_	1 1		84	55	64	271/2	24	21	6	6	450	750		14	14	\square		86					30/2 3	3 21	8	6	6	11/2	16		(6)500MCM	(3)500MCM	9,250	9,550	5,500	5,800
1440	4717	-5-	┝┋╴	1817	1742	_	1 1		84	55	64	271/2	24	21	6	6	450	750		14	14	\square		86				-	30/2 3			6	6	11/2	16	/\	(6)500MCM	(3)500MCM	8,350	9,650	5,600	5,900
1530	5012	— <u>IS</u> —	<u> </u>	1931	1852		1 /\	_	84	55	64	271/2	24	21	6	6	450	750	1 /	14	14	$\sqcap\sqcap$		100			67	_	331/2 3	5 21	8	6	6	11/2	17	/\	(9)500MCM	(3)500MCM	9,450	9,750	5,700	6,000
1620	5307	_ᇊ_	⊢ÿ.	2044	1960	_			84	55	64	271/2	24	21	6	6	450	750		14	14		100	100	//	90	67	_	331/2 3	5 21	8	6	6	11/2	18	/ \	(9)500MCM	(3)500MCM	9,550	9,850	5,800	6,100
1710	5601	_ ĭ _	_ ~ _	2158	2069			1 8	84	55	64	271/2	24	21	6	6	450	750		14	14		100	100		90	67	-	331/2 3	5 21	8	6	6	11/2	19	/ \	(9)500MCM	(3)500MCM	9,650	9,950	5,900	6,200
1800	5896			2272	2178	1820		1 8	84	55	64	271/2	24	21	6	6	450	750		14	14		100	100		90	67	76	331/2 3	5 21	8	6	6	11/2	20	7 \	(9)500MCM	(3)500MCM	9,750	10,050	6,000	6,300
1920	6289			2423	2322	1941		1 8	86	61	64	301/2	34	23	8	8	600	1075	Ш	14	14		100	100		92	79	88	391/2 3	5 21	8	6	8	11/2	16		(9)500MCM	(3)500 MCM	12,800	14,700	7,800	9,400
2040	6683			2574	2468		$\Box T$			61	64	301/2	34	23	8	8	600	1075	\prod	14	14			100	-		••		391/2 3	_	8	6	6	11/2	17	I = I	(6)500MCM	(3)500MCM	15,000	14,900	8,000	9,600
2160*	7076			2725					86	61	76	301/2	35	23	8	8	600	1075	Ш	14	14	$\coprod \coprod$		100					391/2 3			6	6	11/2	18		(6)500MCM	(3)500 MCM	15,100	15,100	8,100	9,800
2280*	7469			2876						67	76	331/2	35	23	8	8	600	1075	Π	14	14		100						391/2 3			6	6	2	19		(6)500MCM	(3)500 MCM	15,300	15,300	9,400	10,000
2400*	7862		$\sqcup \!\!\! \perp$	3027	2902					67	76	331/2	35	23	8	8	750	1075	Ш	14	14		100						391/2 3				8	2	20	1	(6)500MCM	(3)500 MCM	15,500	15,500	9,400	10,200
2520*	8255			3179			$\perp \!\!\! \perp$			67	76	331/2	35	23	8	8	750	1075	$\perp \!\!\! \perp \!\!\! \perp \!\!\! \perp$	14	14		100						391/2 3				8	2	21	1	(6)500MCM	(3)500MCM	15,600	15,700	9,400	10,400
2640*	8648			3329	3192		\parallel	1 8		67	76	331/2	35	23	8	8	750	1075		14	14		100	100					391/2 3				8	2	22	1	(6)500MCM	(3)500MCM	16,200	15,900	10,000	10,600
2760*	9041			3480			+			67	76	331/2	35	23	8	8	750	1072		14	14		100						391/2 3				8	2	23	1	(6)500MCM	(3)500MCM	16,400	16,100	10,200	10,800
2880*	9434	\bot	\sqcup	3632	3482		\perp		92	79	88	391/2	38	23	8	8	1075	1075	1	14	14		100						391/2 3				8	2	24		(6)500MCM	(3)500MCM	16,700	16,300	10,500	11,000
3000*	9828	▼		3782	3626	3029		,	92	79	88	391/2	38	23	8	8	1075	1075		14	14		100	lω		92	79	88	391/2 3	8 21	10	6	8	2	25		(9)500MCM	(3)500MCM	16,900	16,500	10,700	11,200

* Boilers 2100 and larger reqire two (2) power panels.

Note: Dimensions and specifications subject to change without notice. Consult factory for certified dimensions.

